



COFONE CONSULTING GROUP, LLC

CHRISTINE A. COFONE, PP, AICP
Principal

November 8, 2017

Lance B. Landgraf, Jr., P.P., AICP
Director of Planning
Casino Reinvestment Development Authority
15 South Pennsylvania Avenue
Atlantic City, NJ 08401

RE: **Bashu Dev**
123 N. Georgia Avenue (Rear)
Block 338, Lot 9
Application #2017-11-2285

Dear Mr. Landgraf:

We have deemed this application **complete** for review.

In the subject application, the applicant is seeking site plan approval, with “c” variances,” to demolish a two-story single-family home and rebuild a single-family detached dwelling at required elevation height within the footprint of the former structure. Additional improvements are proposed, as detailed in this report.

As part of our analysis, we undertook the following tasks: an inspection of the subject premises; a survey of surrounding land uses; review of the City of Atlantic City Zoning Ordinance and Zoning Map; review of the applicant’s application submission package; review of relevant case law related to the granting of variances; review of a “Land Title Survey Zoning Plan” prepared by Robert J. Catalano, PLS consisting of 1 sheet, dated July 1, 2016 and revised to August 4, 2017; elevations, floor plans, and construction sequence plan consisting of 8 sheets prepared by Edward J. Kellner, NJ Architect, of Robert E. Bolton Associates undated and revised to April 29, 2017; a CRDA application dated May 24, 2017.

We offer the following analysis and comments for your consideration.

Description of Site and Summary of Development Proposal

The property in question was once developed with a single-family dwelling designated as Block 338, Lot 9 on the official tax maps of the City of Atlantic City at 123 N. Georgia Avenue (Rear) with frontage on Blake Street.

125 Half Mile Road, Suite 200 • Red Bank, New Jersey 07701 • Office: 732.933.2715 • Fax: 732.933.2601 • Cell: 732.439.6400

E-mail: ccofone@cofoneconsulting.com • www.cofoneconsulting.com



CHRISTINE A. COFONE, PP, AICP
Principal

COFONE CONSULTING GROUP, LLC

The applicant is seeking seeking site plan approval, with “c” variances,” to built a single-family detached dwelling at required elevation height (12.00 N.A.D. 1988 Datum) within the footprint of the former structure. The applicant also proposes partially enclosed steps and landing, at grade level storage, an elevated porch, and a second story deck. Note that the Applicant has already demolished the structure previously on the site, which was damaged by Superstorm Sandy. A new concrete footing and foundation has been constructed in the same location.

Surrounding Land Uses

The subject property is located within a row of single-family attached homes along North Georgia Avenue in the Ducktown section of the city.

Zoning Compliance

The property is located in the Single-Family Attached (Townhouse) Residential (R-3) Zone District. As stated at Ordinance Section 163-55(A)(2), the purpose of the R-3 Zone is as follows:

The R-3 Single-Family Attached Residential District has been established to foster townhouses and duplexes at areas in the City where such housing types have prevailed and developed in an orderly fashion, as well as in other areas suitable for attached single-family dwellings.

The application requires the following “c” variances:

Existing, non-conforming conditions:

- Minimum lot area: 3,000 sf required; 1,224 sf existing and proposed
- Minimum lot width: 40’ required; 18’ existing and proposed
- Minimum lot depth: 90’ required; 68’ existing and proposed

Newly created variances:

- Maximum lot coverage: 40% required; 72.7% proposed
- Minimum front yard setback: 10’ required; 4.3’ proposed
- Minimum rear yard setback: 25’ required; 8.7’
- One side yard setback: 12’ required; 1.08’ proposed

125 Half Mile Road, Suite 200 • Red Bank, New Jersey 07701 • Office: 732.933.2715 • Fax: 732.933.2601 • Cell: 732.439.6400

E-mail: ccofone@cofoneconsulting.com • www.cofoneconsulting.com



CHRISTINE A. COFONE, PP, AICP
Principal

COFONE CONSULTING GROUP, LLC

- Second side yard setback: 5' required; 0.72' proposed

Master Plan Review

The subject property is located within the Atlantic City Tourism District. Pursuant to the New Jersey CRDA Atlantic City Tourism District Master Plan, the overall intention and vision is to “reinvigorate Atlantic City in the near-term as the leading resort destination in the Northeast and beyond (Page 4, New Jersey CRDA Atlantic City Tourism District Master Plan). Among others, overarching objectives are to “develop an economically viable and sustainable tourism district” and “[expand] Atlantic City’s tourism and economic bases” (Id, Page 1-2).

Planning Analysis and Issues for Consideration by the Board

In regard to the “c” variances, the Municipal Land Use Law (MLUL) at NJSA 40:55D-70c sets forth the standards for variances from the bulk regulations of a zoning ordinance. A “c(1)” variance is for cases of hardship due to factors such as shape or topography, or due to “an extraordinary and exceptional situation uniquely affecting a specific piece of property or the structures lawfully existing thereon.” A “c(2)” variance may be granted where the purposes of zoning are advanced and the benefits of deviating from the ordinance requirements outweigh any detriments. The benefits derived from granting a “c(2)” variance must include benefits to the community as a whole, not just to the applicant or property owner. A “c” variance application also must address the “negative criteria.”

We offer the following for your consideration in reviewing the Application:

- 1) The applicant requires “c” bulk variances as detailed earlier in this report. The applicant’s professional planner shall provide the requisite statutory proofs.
- 2) The Applicant previously received approval for a demolition and rebuilt on the property, with variances granted, on November 15, 2016. The Applicant shall describe the changes in the current application.
- 3) The applicant’s surveyor/planner should revise the zoning table to accurately reflect the R-3 Zone standards.
- 4) Schedule I of the Atlantic City Land Use Development Ordinance does not include a building coverage requirement. The Applicant has called out this variance but it is not needed.

125 Half Mile Road, Suite 200 • Red Bank, New Jersey 07701 • Office: 732.933.2715 • Fax: 732.933.2601 • Cell: 732.439.6400

E-mail: ccofone@cofoneconsulting.com • www.cofoneconsulting.com



CHRISTINE A. COFONE, PP, AICP
Principal

COFONE CONSULTING GROUP, LLC

- 5) The applicant shall discuss parking.
- 6) The applicant shall provide testimony whether there will be any landscaping improvements.
- 7) The applicant shall provide testimony by its architect relative to the proposed architectural elements, discussing the proposed elevations and floor plan. Even with the increase in building height to comply with the base flood elevation (BFE), the applicant's proposed height (<35') complies with the zone district's maximum requirement (35'). The applicant shall discuss the required BFE. Atlantic City requires a BFE plus two feet for a new first floor elevation. How does the applicant intend to flood proof the home?
- 8) The applicant shall provide testimony relative to how the proposed improvements advance the intent of the New Jersey CRDA Atlantic City Tourism District Master Plan and the Tourism District.

We would be happy to address any questions or comments on the above at the public hearing.

Respectfully submitted,

Christine A. Nazzaro-Cofone, AICP, PP
CRDA Consulting Planner

cc: Robert L. Reid, AICP, PP, Land Use Regulation Enforcement Officer
Paul G. Weiss, Esq., Chief Legal Counsel
William England, PE, Board Engineer
Applicant's Attorney
Applicant's Engineer