



CE #19/2

February 22, 2019

Atlantic City Convention Center
1 Convention Boulevard,
Atlantic City, NJ 08401

Attn: Jason Resetar

Re: Old Pump Vaults

Calvi Electric responded to a job to trace the old pump power wires located in the pump vaults at the Atlantic City Convention Center. We also were to verify that they were de-energized or de-energize them if necessary. We were directed by representatives from the Convention Center and the CRDA as to what vaults to check after tracing the wires we found them to be de-energized and traced them back to the old pump station on Ohio Ave. During the tracing process we removed the wire from the motor control center in the pump station and did not re-terminate them as directed by CRDA. Also, there is no electric being supplied to the building at this time so there is no way for the wires in the vaults to become energized.

As a secondary check to ensure that any wiring present in the pump vaults is not in any way part of or connected to the site lighting for the Atlantic City Convention Center, the Atlantic City Convention Center Staff energized the outside lighting circuits and wires were tested for voltage; the result was that no voltage was present. Furthermore, based on the location of the pump vaults and direction of the conduit path it appears there is no connection to the adjacent property (Sheraton Hotel).

CALVI ELECTRIC COMPANY

A handwritten signature in black ink, appearing to read 'H. Beckman', is written over the company name.

Henry Beckman / Service Superintendent