

April 23, 2019

To: All Interested Contractors

Re: Bid for Abandonment of Groundwater Treatment system re-solicitation

Addendum 2

This Addendum sets forth the Q&A for questions received by the CRDA website pursuant to section 1.5 of the Bid documents before the Q&A deadline of April 15, 2019 at 12:00 pm. Any questions received after the deadline will not be entertained.

Q1: Who will order and confirm utility disconnects for the groundwater treatment building?

A1: The CRDA will arrange all utility disconnects and provide the contractor with disconnect documentation needed to obtain a demolition permit from the City of Atlantic City.

Q2: Who is responsible for permits and permit fees?

A2: It is the contractor's responsibility to apply for all necessary permits and pay all permit fees.

Q3: One of the collection wells is located in a striped pedestrian walkway. After filling the well and capping with asphalt do the lines need to be replaced?

A3: Yes, the contractor should replace in kind any disturbed lines.

Q4: Will a road closure permit be needed for the work in the bus lane?

A4: The bus lane is the property of the Convention Center and as such will not be subject to a road closure permit. Convention Center staff will block the lanes off as needed.

Q5: There is a metal gate and an asphalt driveway at the pump facility on Ohio Avenue. Do these get removed?

A5: Yes.

The bidder is responsible to ensure that all changes necessitated by Addenda are accounted for and incorporated into the bidder's response to the

Solicitation. All instructions, terms and conditions of the Contract Documents shall remain unchanged, unless expressly modified by the Authority.